



**BUREAU
VERITAS**

Certificate for the NS protection

Manufacturer / applicant: KACO new energy GmbH
Carl-Zeiss-Straße 1
74172 Neckarsulm
Germany

Type of grid and plant protection:	Integrated NS protection
Assigned to generation unit type:	blueplanet gs 10.0TL3 M2B1 WM ID IIGS

Firmware version: Controller: 4.7; Com: 4.1

Connection rule: VDE-AR-N 4105:2018-11 – Power generation systems connected to the low-voltage distribution network

Technical minimum requirements for the connection to and parallel operation with low-voltage distribution networks.

Applicable standards / directives: DIN VDE V 0124-100 (VDE V 0124-100):2019-11 – Grid integration of power generation systems – low voltage

Test requirements for power generation units to be connected and operated parallel with the low-voltage distribution networks

The above mentioned grid and plant protection has been tested and certified according to the test guideline VDE 0124-100. The electrical properties required in the connection rule are satisfied.

- Setting values and disconnect times
- Properly functioning functional chain "NS protection – interface switch"
- Technical requirements of the switching device
- Passive detection of stand-alone power systems
- Single-fault tolerance

The certificate contains the following information:

- Technical specifications of the NS protection and corresponding power generation types
- Setting values of the protection functions
- Trip values of the protection functions

BV project number: 19TH0305-ARN4105-2018_0

Certification program: NSOP-0032-DEU-ZE-V01

Certificate number: U20-0078

Date of issue: 2020-02-20

Certification body



Holger Schaffer



Certification body of Bureau Veritas Consumer Products Services Germany GmbH Accredited according to DIN EN ISO/IEC 17065

A partial representation of the certificate requires the written permission of Bureau Veritas Consumer Products Services Germany GmbH

E.7 Requirements for the test report for the NS protection

Extract from test report for NS protection

Nr. 19TH0305-ARN4105-2018_0

“Determination of electrical properties”

NS protection as integrated NS protection

Manufacturer / applicant:	KACO new energy GmbH Werner-von-Siemens-Allee 1 74172 Neckarsulm Germany
Type of grid and plant protection:	Integrated NS protection
Assigned to generation unit type:	blueplanet gs 10.0TL3 M2B1 WM ID IIGS
Firmware version:	Controller: 4.7; Com: 4.1
Integrated interface switch:	Type of switching equipment 1: Relay Type of switching equipment 2: Relay
Measurement period:	2019-05-15 to 2019-11-06

Inverter / direct coupled synchron and asynchrone generators with $P_n > 50kW$

Protection function	Setting value	Trip value	Disconnection time ^a
Voltage drop protection U <	184,0 V	182,7 V	3000 ms
Voltage drop protection U <<	103,5 V	102,6 V	325 ms
Rise-in-voltage protection U>	253,0 V	--	524 s ^b
Rise-in-voltage protection U>>	287,5 V	285,6 V	199 ms
Frequency decrease protection f<	47,50 Hz	47,50 Hz	142 ms
Frequency increase protection f>	51,50 Hz	51,50 Hz	142 ms

^a proper time of interface switch 2 ms

^b longest disconnection of the rise-in-voltage protection as a moving 10-minute-average, tested according clause 5.5.7 Protection devices and protection settings of VDE 0124-100

The disconnect time (sum of trip time of grid and plant protection and delay time of interface switch) must not exceed 200 ms.

A check of the overall functional chain "NS protection – interface switch" resulted in a successful disconnection.

The above mentioned grid and plant protection with the assigned power generation units has met the requirements for islanding detection with the help of the passive method (three-phase voltage monitoring).

The above mentioned NS protection meets the requirements for synchronization.